

Technical and Economic Feasibility of Remote Area Hydrocarbon Exploitation
Using a Clean Energy Producing Vessel

by

Dr Richard Bucknall

The LRET Research Collegium
Southampton, 11 July – 2 September 2011

‘On the Technical and Economic Feasibility of Remote Area Hydrocarbon Exploitation Using a Clean Energy Producing Vessel’

Richard Bucknall

**Marine Research Group
Department of Mechanical Engineering
University College London
r_bucknall@meng.ucl.ac.uk**

Lecture Format


- Energy and Emissions
- The CEPV Concept
 - Prime-mover Options
 - Gas Flows and Separation
 - Electrical Power Transmission Schemes
 - CO₂ Capture and Sequestration
 - Economic Analysis
 - Case Studies
- Conclusions

ENERGY AND EMISSIONS

Energy and Greenhouse Gases



Worldwide Energy Supply Today




Source: IEA

- Hydrocarbons (oil, gas and coal) supply 87% of our energy needs.
- Nuclear Fission supplies only 6% of our energy needs.
- Renewables supply only 7% of our energy needs and is predominantly large scale hydro-electric schemes.

Today the world uses nearly twice as much energy as it did 30 years ago!

World CO2 Emissions Today




The worst polluters are:

- Electricity (0.45 kg/kWh)
(mixed primary energy)
- Coal (0.35 kg/kWh)
(industry and heating)
- Oil (0.27 kg/kWh)
(industry and transport)
- Gas (0.22 kg/kWh)
(industry and heating)

Electricity – A Worldwide Perspective

- Major contributor to Greenhouse Gas Emissions
- Rapidly increasing demand
 - Mainly met by new fossil thermal power stations!!!



Electricity – A UK Perspective

- Major contributor to Greenhouse Gas Emissions
- Security of Energy Supply
- Future Generation Gap (old power stations)

| Type | No. of Stations | No. of Stations Over 30 Years Old | % |
|--------------|-----------------|-----------------------------------|-------------|
| Gas | 19 | 14 | 73.7 |
| Coal | 16 | 13 | 81.3 |
| Nuclear | 12 | 6 | 50 |
| Wind | 66 | 0 | 0 |
| Hydro | 73 | 61 | 83.6 |
| CCGT | 35 | 0 | 0 |
| Oil | 3 | 1 | 33.3 |
| CHP | 5 | 0 | 0 |
| Other | 24 | 12 | 50 |
| Total | 253 | 107 | 42.3 |

Summary

- There is an ever increasing demand for energy worldwide.
- Electricity consumption accounts for a growing proportion of total energy demand
- Electricity is predominantly generated using hydrocarbon fuels using large (GW) power stations
- CO₂ emissions from electricity are a cause of global warming

THE CEPV CONCEPT


Assumptions

- Gas is the preferred fossil fuel as it produces less emissions than coal and oil. Renewables and nuclear are small and likely to remain so.
- UK has its own natural gas resources but is increasingly is dependent on imports.
- Majority of UK gas is offshore.
- These also apply to other nations.




UK Gas Fields

Southern North Sea gas field distribution showing how gas is not in a single large field but is found in many small pockets each requiring its own 'tap and pipe'.




World Energy Resources



Significant amounts of natural gas is simply uneconomic to recover using pipeline!

The CEPV Concept



Onshore and Offshore Power Generation

Onshore

- Gas is supplied
- Gas supply is 'clean' gas
- Gas is at 'market price'
- Conventional power plant
- Housed in a building
- Connection direct to NG
- Fixed location
- CCS requires long pipeline
- Known technical solution
- Known capital and running costs

Offshore

- Gas must be drilled
- Gas supply is 'raw' gas
- Gas is abandoned i.e. 'free'
- 'Marinised' power plant
- Housed in a vessel or rig
- Connection is via subsea cable
- Location not fixed
- CCS requires shorter pipelines
- Unknown technical solution
- Unknown capital and running costs

Cost Comparison

| Parameter | Shore-based Power Station | Offshore-based Power Station |
|---------------------|--|---|
| Capital Cost | <ul style="list-style-type: none"> ▪ Land purchase ▪ Power station ▪ Connection to gas supply ▪ Connection to National Grid ▪ Service requirements | <ul style="list-style-type: none"> ▪ Licence to exploit natural gas ▪ Wellhead cost and riser ▪ Vessel ▪ Gas processing plant ▪ Power generating plant ▪ Subsea transmission cable ▪ Connection to National Grid |
| Running Cost | <ul style="list-style-type: none"> ▪ Gas consumption ▪ Cooling water charges ▪ CO₂ emissions tax ▪ National Grid connection cost ▪ Maintenance cost ▪ Manning cost ▪ Taxes | <ul style="list-style-type: none"> ▪ National Grid cost ▪ Maintenance cost ▪ Manning cost ▪ Taxes |

Key parts of a 'Base Case' CEPV

- Power Generation
 - Prime-movers
 - Electrical generation and distribution
 - Electrical power transmission
- Gas Side
 - Well head and riser system
 - Onboard gas processing plant
 - CO₂ Capture, compressing and storage (optional)
- Platform
 - Vessel
 - Ship services
 - Propulsion (optional)


Prime-movers



Prime-mover Selection Criteria

| PRIME-MOVER TYPE | ADVANTAGES | DISADVANTAGES |
|-----------------------|---|---|
| DIESEL | <ul style="list-style-type: none"> Large range of powers Cheap £/kW Good efficiency 'Marinised' engines available | <ul style="list-style-type: none"> Limited versions use NG High maintenance |
| GAS TURBINES | <ul style="list-style-type: none"> Good power to weight ratio High powers available Some 'marinised' engines | <ul style="list-style-type: none"> Low efficiency Discrete size engines Expensive £/kW |
| STEAM TURBINES | <ul style="list-style-type: none"> Low maintenance High powers available Robust and 'marinised' plant | <ul style="list-style-type: none"> Heavy plant (requires boilers and condensers) Low efficiency |
| FUEL CELLS | <ul style="list-style-type: none"> Excellent efficiency Low maintenance Modular construction | <ul style="list-style-type: none"> Limited versions available Very expensive £/kW Almost no use offshore |

Combined Cycle Gas Turbine Plant.



High efficiency through waste heat recovery.



Power Plant Selected for Base Case CEPV - Combined Cycle Gas Turbine (CCGT)

Specification

A 264 MW_e Rolls Royce Trent plant which consists of 4 x 51.9 MW_e gas turbine generator and 2 x 28.2 MW_e steam turbine generator operating using the waste heat generator.

Maximum Gas In-Flow Calculations

- **Intake air:** 12.32 million m³ per day
- **Gas consumption:** 1.24 million m³ per day

Maximum Gas Out-Flow Calculations

Minimum Capacity for Base Case CEPV:

- **Exhaust:** 33.7 million m³ per day
- **CO₂:** 1.31 million m³ per day

CEPV – Natural Gas Flows


1. A natural gas flexible riser system ‘up-pipe’ allows ‘raw’ natural gas to be transferred from the wellhead to the CEPV.
2. Gas processing system ‘cleans’ the ‘raw’ natural gas prior to combustion by the CCGT power plant.
3. Condensates collected during gas processing are stored for later transfer to a shuttle tanker.

'Raw Natural Gas'

| Constituent | % Volume | Constituent | % Volume |
|------------------|----------|-----------------|----------|
| Methane | 93.00 | Hexane | 0.05 |
| Ethane | 3.00 | Heptane | 0.03 |
| Propane | 0.67 | Octane | 0.01 |
| Isobutane | 0.27 | Nitrogen | 2.12 |
| Isopentane | 0.08 | CO ₂ | 0.34 |
| H ₂ S | 0.43 | Condensate | 0.05 |


Typical Constituents in North Sea Natural Gas

Gas Flow Rate




Process flow of gas to exhaust to exhaust and electrical power generation.

Gas Processing Plant - Wellhead to CCGT Plant




Transmission


- Electrical power conditioning prepares the generated electrical power for subsea transmission.
- A subsea electrical transmission system connects the CEPV to the shore-side electrical grid.



Proposed Bipolar HVDC System




Typical HVDC ICR Subsea Cable



| Operation mode | Cable type | Voltage (kV) | Conductor material | Conductor CSA (mm ²) | Cost (£/m) | Losses (MW/km) | Converter cost (£) | Additional losses (%) |
|----------------|------------|--------------|--------------------|----------------------------------|------------|----------------|--------------------|-----------------------|
| HVDC | ICR | 200 | aluminium | 1000 | 142 | 0.051 | 50 M | 5* |



Cable Costs



CEPV Electrical Power System

| Equipment | Specifications | Manufacturer |
|-----------------------------------|--|--|
| Generators | 6 x AC Synchronous Brushless Generators operating at 50 Hz and 25 kV: <ul style="list-style-type: none"> ▪ 4 x 61.1 MVA ▪ 2 x 33.2 MVA <i>Volume : 2,506 m³</i> | GT Generators are supplied as part of Rolls Royce Trent package. ST Generators are supplied as part of Alstom steam turbines generator package. |
| Transformers | 1 x Step-up Transformer on CEPV <i>Volume : 630 m³</i> | Siemens Power Transmission and Distribution |
| Converters | VSC Converter/Inverter <i>Volume : 13,000 m³</i> | ABB HVDC Light |
| Cable type | HVDC: 200 kV ICR Cable | ICR: Nexans Cables |
| Generator Circuit Breakers | Water-cooled, continuous current ratings up to 8,000 A <i>Volume : 80 m³</i> | Hitachi GMCB SF6 |

CLEAN ENERGY PRODUCING VESSEL

| | | | |
|-------------------|-----------------|-------------------------|---------------|
| DEEP DISPLACEMENT | 67,037 TONNES | LIGHT SHIP DISPLACEMENT | 62,026 TONNES |
| LENGTH (BP) | 179 M | LENGTH (OA) | 185 M |
| BEAM (WL) | 34 M | DEPTH OF HULL | 19 M |
| C _P | 0.86 | C _M | 0.98 |
| STORES | 30 DAYS MAXIMUM | COMPLEMENT | 20 |
| OPERATIONAL AREA | NORTH SEA | HULL TYPE | MONO-HULL |

PAYLOAD

GAS PROCESSING PLANT

CO₂ SEQUESTRATION PLANT

GAS TURBINE AND STEAM TURBINE GENERATORS

SUBMERGED TURRET PRODUCTION SYSTEM


MACHINERY


| GAS PROCESSING PLANT | ELECTRICITY GENERATING PLANT | ELECTRICAL EQUIPMENT | OTHER |
|-------------------------|--|--------------------------------------|---|
| 3-PHASE SEPARATOR | 4X ROLLS ROYCE TRENT GAS | 1X SIEMENS POWER TRANSFORMER | 1X APL SUBMERGED TURRET PRODUCTION UNIT 1x condensate offloading facility |
| Amine gas sweetener | TURBINES AND GENERATOR | 1x Siemens switchgear | |
| Glycol dehydration unit | 2x Alstom WHRU steam turbine and generator | 1x Hitachi GCMCB sf6 circuit breaker | |
| Gas compressor | 4x Wartsila diesel generators | 1x ABB HVDC Light converter station | |

TANKAGE


| | | | |
|-------------|----------------------|-----------------------|--------------------|
| CONDENSATE | 1,000 M ³ | SLUDGE AND WASTE OILS | 250 M ³ |
| FRESH WATER | 400 M ³ | NATURAL GAS BUFFER | 900 M ³ |

CEPV – Outline Design Study





PROFILE





Specification of the Base Case CEPV

| Equipment | Specifications/Requirements | Comments |
|---|---|--|
| CCGT electricity generating plant | CCGT Plant for Base CEPV: A 264 MW _e Rolls Royce Trent plant which consists of 4 x 51.9 MW _e gas turbine generator and 2 x 28.2 MW _e steam turbine generator. <u>Volume: 11,713 m³</u> | <ul style="list-style-type: none"> - Intake air: 12.32 million m³ per day. - Fuel consumption: 1.24 million m³ per day. - Exhaust Generated: 33.7 million m³ per day. |
| Gas Processing Plant | Gas processing plant to consist of a three phase separator, condensate offloading facility, amine sweetener, glycol dehydration plant, natural gas buffer and emergency flare. <u>Volume: 13,500 m³</u> | <ul style="list-style-type: none"> - Minimum gas flow for Base Case CEPV: 41 mmscfd. - Natural gas required: 1.24 million m³ per day. - Condensate production: 6.37 m³ per day. 1x MAN Turbo Compressor |
| CO ₂ Capture and Sequestration | Post-combustion capture with geological sequestration into depleted oil and gas field. | Minimum Capacity for Base Case CEPV: 33.7 million m ³ exhaust gas per day. 1.313 million m ³ CO ₂ per day. |
| Turret | Turret to accommodate: natural gas up-pipe, CO ₂ down-pipe and cable riser | Natural gas: 41 mmscfd CO ₂ 1.313 million m ³ per day 250 MWe generated electricity |

CO₂ Capture and Sequestration

- CCS is a technology under development.
- Different solutions for capture are being researched
- Different solutions for storage are being researched




Carbon Capture and Storage Schemes

| Project name | Country | Injection start (year) | Approximate average daily injection rate (tCO ₂ day ⁻¹) | Total (planned) storage (tCO ₂) | Storage reservoir type |
|-------------------|-------------|------------------------|--|---|------------------------|
| Weyburn | Canada | 2000 | 3,000-5,000 | 20,000,000 | EOR |
| In Salah | Algeria | 2004 | 3,000-4,000 | 17,000,000 | Gas field |
| Sleipner | Norway | 1996 | 3,000 | 20,000,000 | Saline formation |
| K12B | Netherlands | 2004 | 100 (1,000 planned for 2006+) | 8,000,000 | Enhanced gas recovery |
| Frio | U.S.A | 2004 | 177 | 1600 | Saline formation |
| Fenn Big Valley | Canada | 1998 | 50 | 200 | ECBM |
| Qinshui Basin | China | 2003 | 30 | 150 | ECBM |
| Yubari | Japan | 2004 | 10 | 200 | ECBM |
| Recopol | Poland | 2003 | 1 | 10 | ECBM |
| Gorgon (planned) | Australia | ~2009 | 10,000 | unknown | Saline formation |
| Snøhvit (planned) | Norway | 2006 | 2,000 | unknown | Saline formation |

Examples of some current Carbon Capture and Storage Technologies.

CO₂ Separation

- Separate CO₂ from exhaust (Capture process)
- Capture processes
 - Calcium cycle capture
 - Cryogenic capture
 - Amine capture
- CEPV selected ABB-Lummus System
 - 6,290 m³ of CO₂ per hour on a single stream



Transportation of CO₂

- The transportation of CO₂ by ships is already being done but only on a small scale. Larger ships would be required for the sequestration of CO₂
- The CO₂ is generally transported as a pressurised cryogenic liquid e.g. at 6 bar and at a temperature of -55 deg. C - energy intensive process.
- The CEPV avoids the need to transport CO₂. CO₂ would simply be transported in short pipelines to a CO₂ wellhead.

CO₂ Sequestration

- Existing technology already in use for CO₂ enhanced oil recovery. CO₂ is easily handled and is large inert, it can be transported at high pressures through pipelines.
- There is extensive pipelines carrying CO₂ in existence some of which are offshore.
- There are internationally recognised standards for the design, construction and monitoring of pipelines carrying CO₂ offshore and onshore.


CEPV Economic Model

Input Page:

- Financial information
- Plant Technical Data
- Field Information Data
- Transmission Data

Output Page:



- CAPEX, OPEX
- IRR, PP, NPV



Output Page



| | | Gas-to-Wire | |
|----------------|-------------------------------|----------------------|------------------|
| CAPEX | | | |
| | Vessel | | |
| | Basic Vessel | 66.3 | (all £M) |
| | Generator Set | 153.7 | |
| | Sequestration Plant | 0.0 | |
| | Electrical Equipment | 44.2 | |
| | Platform | | |
| | Structure | - | |
| | Processing Plant | - | |
| | Wells and Subsea Installation | 56.1 | |
| | Risers (Dynamic) | 2.8 | |
| | Transmission Cables | 57.5 | |
| | Pipeline | - | |
| | Onshore Electrical Equipment | 44.2 | |
| | Connections | 0.1 | |
| | Miscellaneous | 0.0 | |
| | Relocations | 0.0 | |
| | Decommissioning | 12.7 | |
| | | Total | 437.4 £M |
| OPEX | First year | 17.3 | £M |
| | | Total | 258.4 £M |
| REVENUE | Revenue per year (max.) | 98.5 | £M |
| | | Gross Revenue | 1477.2 £M |
| IRR | Post Tax | 13.97 | % |
| | Pre Tax | 19.42 | % |
| NPV | NPV at 5% | 241.1 | £M |
| PAYBACK | Payback Period | 6.6 | years |

Results: Impact of Electricity Sales Price






- CEPV demonstrates satisfactory payback and IRR provided electricity price is about £60/MWhr
- An upward trend of electricity price is desirable to ensure profitability

Impact of Distance of Shore and Water Depth



- Generally, further offshore means greater depth and increased costs for cable and up and down pipes.
- However the impact on IRR and payback is modest.

Impact of Relocations



- Increasing the number of wells allows increased gas flow as the gas field depletes but is more expensive.
- Increasing the number relocations (which will include down time) means reduced IRR and increased payback.


Economics of CO₂ Sequestration

| Parameter | Without CO ₂ Sequestration | With CO ₂ Sequestration |
|----------------------|---------------------------------------|------------------------------------|
| IRR (%) | 19.42 (13.97) | 6.27 (3.28) |
| PP (Years) | 6.6 | 11.7 |
| NPV (£M) | 241.1 | -57.3 |
| CAPEX (£M) | 437.4 | 595.3 |
| First Year OPEX (£M) | 258.4 | 327.7 |



- The impact of using CO₂ Sequestration was found to be detrimental to the economic viability of the Base Case CEPV without CO₂ CCS.
- Further studies looked at the level of subsidy required and/or Carbon Tax to make the CEPV with CO₂ Sequestration economic.

Power Plant and Generator Set Options


| Gen Set | Output (MWe) | η (%) | Total NG req. per day (tonne) | Minimum gas flow to achieve maximum production (mmscf/d) | Total NG prod. per day (tonne) | Volume of NG prod. per day (million m ³) | O ₂ req. per day (tonne) | Volume of intake air req. per day (million m ³) | CO ₂ prod. per day (tonne) | Volume of CO ₂ prod. per day (million m ³) |
|---------|--------------|------------|-------------------------------|--|--------------------------------|--|-------------------------------------|---|---------------------------------------|---|
| 1 | 258 | 37 | 1244 | 64 | 1256 | 1.76 | 4990 | 17.52 | 3481 | 1.87 |
| 2 | 250.8 | 51 | 877 | 45 | 883 | 1.24 | 3508 | 12.32 | 2447 | 1.31 |
| 3 | 502 | 52 | 1722 | 88 | 1726 | 2.42 | 6861 | 24.09 | 4786 | 2.57 |
| 4 | 279 | 52 | 957 | 49 | 961 | 1.35 | 3820 | 13.42 | 2665 | 1.43 |
| 5 | 264 | 54 | 872 | 45 | 883 | 1.24 | 3508 | 12.32 | 2447 | 1.313 |
| 6 | 267 | 51 | 934 | 48 | 942 | 1.32 | 3742 | 13.14 | 2611 | 1.4 |
| 7 | 263.2 | 54 | 869 | 45 | 883 | 1.24 | 3508 | 12.32 | 2447 | 1.313 |
| 8 | 157 | 54 | 519 | 27 | 530 | 0.74 | 2105 | 7.39 | 1468 | 0.79 |
| 9 | 264 | 54 | 872 | 45 | 883 | 1.24 | 3508 | 12.32 | 2447 | 1.313 |
| 10 | 328 | 49 | 1194 | 61 | 1197 | 1.68 | 4756 | 16.7 | 3318 | 1.779 |
| 11 | 400 | 54 | 1321 | 68 | 1334 | 1.87 | 5302 | 18.62 | 3698 | 1.98 |
| 12 | 502 | 52 | 1722 | 88 | 1726 | 2.42 | 6861 | 24.09 | 4786 | 2.57 |
| 13 | 259.5 | 42 | 1102 | 57 | 1118 | 1.57 | 4444 | 15.61 | 3100 | 1.66 |
| 14 | 258 | 55 | 837 | 43 | 844 | 1.18 | 3352 | 11.77 | 2339 | 1.25 |




Case Study – Clair Field



Clair Field is West of Shetland and is mainly an oil field with natural gas.



Case Study – Bonga Field



| Options | CAPEX (£M) | OPEX (£M) | NPV (£M) | IRR (%) | PP (Years) | Power Gen. (MW) | Power Exp. (MW) | Viability | Ranking |
|---------|------------|-----------|----------|---------|------------|-----------------|-----------------|-----------|---------|
| 1 | 521 | 118.1 | 31.4 | 6.46 | 7.4 | 258 | 245.1 | Y | 3 |
| 2 | 601.3 | 132.8 | -124.2 | 0.05 | - | 250.8 | 238.3 | | |
| 3 | 934.2 | 210 | 30.7 | 5.79 | 7.6 | 502 | 476.9 | Y | 4 |
| 4 | 643 | 144.9 | -112.5 | 0.57 | 9.7 | 279 | 265.1 | | |
| 5 | 601.8 | 218.7 | -158.3 | - | - | 264 | 250.8 | | |
| 6 | 537.8 | 117.9 | -31.7 | 3.51 | 8.4 | 267 | 253.7 | | |
| 7 | 535.1 | 109.4 | -79.2 | 1.25 | 9.3 | 263.2 | 250.0 | | |
| 8 | 560.9 | 193 | -288.6 | - | - | 157 | 149.2 | | |
| 9 | 601.8 | 218.7 | -158.3 | - | - | 264 | 250.8 | | |
| 10 | 654.1 | 151 | -5.5 | 4.77 | 7.9 | 328 | 311.6 | | |
| 11 | 695.1 | 166.4 | 91.6 | 8.16 | 8.66 | 400 | 380.0 | Y | 2 |
| 12 | 833.3 | 203 | 127.1 | 8.64 | 6.8 | 502 | 476.9 | Y | 1 |
| 13 | 542.7 | 188.3 | -48.4 | 2.74 | 8.7 | 259.5 | 246.5 | | |
| 14 | 557.3 | 125.3 | -71.5 | 1.76 | 9.1 | 258 | 245.1 | | |

Conclusions

- If the world is serious about reducing global warming through a reduction in emissions then it must either reduce its dependence on fossil fuels or learn to avoid emitting CO₂ into the atmosphere.
- Energy sources are becoming more remote – much lies offshore in remote locations known as stranded gas reserves.
- The CEPV is an offshore power concept that appears technically and economically feasible for exploiting some stranded gas reserves
- The CEPV with CO₂ Sequestration requires subsidy to make it economic although technically feasible to achieve.